

Certificate Number: A020027

Date Issued: 13th December 2002

“Autofill” Pressurisation Unit

Models: AF, AFC, AFS, AFP

Pressurisation unit for filling and continuously pressurising sealed heating systems. Fluid category 4 protection provided by an internal BA device (no filling loop is required). Incorporates servicing valves, strainer, tundish and two gauges. Housed in a lockable wall mounted enclosure. Model AFC has high and low cut-out switches. Model AFS features a solenoid valve and pressure switch in place of a Pressure Reducing Valve. Model AFP includes a booster pump, which boosts the outlet pressure by up to 1.3 bar more than the supply pressure. The supply to the unit may be from a supply pipe or - for tall buildings – a boosted cold water service.

Size: 15 mm & 22 mm

Product Designation: “Autofill” model AF, AFC, AFS, AFP

Markings: Adhesive label stating manufacturer's name, model and installation instructions.

This is to certify that the above range of products manufactured by

Arrow Valves Ltd

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2000, Scotland and the Water Regulations Northern Ireland.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements may be obtained from the installation instructions supplied with the products.

Director
Kiwa Quality Services Ltd

Kiwa Quality Services Ltd
Unit 3
Severn Link distribution Centre
Newhouse Farm Industrial Estate
Chepstow
Gwent
NP16 6UN
UNITED KINGDOM
Tel: 0044 (0) 1291 635840
Fax: 0044 (0) 1291 622250
E-mail: info@kiwa.co.uk
Web: www.kiwa.co.uk

Manufacturer
Arrow Valves Ltd
68 High Street
Tring
Hertfordshire
HP23 4AG
UNITED KINGDOM
Tel: 0044 (0) 1442 823123
Fax: 0044 (0) 1442 823234
E-mail: info@arrowvalves.co.uk
Web: www.arrowvalves.co.uk

