Certificate

kiwa
Partner for progress

UK APPROVAL
Certificate Number: 0903703

Date Issued: 13th March 2009
Date Expired: 13th March 2014

Description: "Boost-A-Break " Break tank and booster set assembly with fluid category 5 protection by virtue of the integral Type AB air gap. Maximum supply pressure 10 bar.

Product Designation: Model BTAB 500, 700, 900, 1200, 4-2, 4-3, 4-4, 3-5, 3-7, 3-10, 5-4, 5-8, 5-10 and 5-16.

This is to certify that the above range of products manufactured / supplied by

Arrow Valves Ltd

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2000, Scotland and the Water Regulations Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRN's) can be obtained from the acceptance letter supplied with this certificate.
Applicable IRN's for this certificate – R001

Authorised Signature

Kiwa Quality Services Ltd

Kiwa Quality Services Ltd
The Innovation Centre
Victoria Park
Festival Drive
Ebbw Vale
Gwent
NP23 8XA
Tel 00 44 (0) 1495 356795
Fax 00 44 (0) 1495 350020
E-mail: info@kiwa.co.uk
Web: www.kiwa.co.uk

Certificate Issued To -

Arrow Valves Ltd
68 High Street
Tring
Herts
HP2 4AG

kiwa approved product
UK WATER SUPPLY REGULATIONS