

Certificate Number: A030562

Date Issued: 22nd January 2004

**Filling valve for filling and continuously pressurising small (typically less than 45kW boiler output) sealed heating systems. Permanent Fluid Category 3 protection provided by a CA device (no filling loop) required. Incorporates a servicing valve, serviceable strainer, tundish, pressure reducing valve and gauge. Size: 15 mm and 22 mm
Product designation: CA296PRV**

This is to certify that the above product manufactured by

Arrow Valves Ltd

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2000, Scotland and the Water Regulations Northern Ireland.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements may be obtained from the installation instructions supplied with the products.

Director
Kiwa Quality Services Ltd

Kiwa Quality Services Ltd
Unit 3
Severn Link distribution Centre
Newhouse Farm Industrial Estate
Chepstow
Gwent
NP16 6UN
UNITED KINGDOM
Tel: 0044 (0) 1291 635840
Fax: 0044 (0) 1291 622250
E-mail: info@kiwa.co.uk
Web: www.kiwa.co.uk

Manufacturer
Arrow Valves Ltd
68 High Street
Tring
Hertfordshire
HP23 4AG
UNITED KINGDOM
Tel: 0044 (0) 1442 823123
Fax: 0044 (0) 1442 823234
E-mail: info@arrowvalves.co.uk
Web: www.arrowvalves.co.uk

